

PERFORMANCE			
LOUVER UNIT SIZE	TOTAL AREA	FREE AREA	FREE AREA
48" x 48"	16 ft ²	9.15 ft ²	57.2%
(1219 x 1219 mm)	(1.49 m ²)	(0.85 m ²)	
BEGINNING POINT OF WATER PENETRATION AT 0.01 oz./ft ² FREE AREA:			1080 FPM

STANDARD CONSTRUCTION

DEPTH:	6" (152 mm)
MATERIAL:	EXTRUDED ALUMINUM - 6063-T5 ALLOY
FRAME THICKNESS:	0.095" (2.41 mm)
BLADE THICKNESS:	0.081" (2.06 mm)
BLADE ANGLE:	55°
BLADE CENTRES:	4.5" (114 mm)
BIRDSCREEN:	19 GA. GALVANIZED BIRDSCREEN - 1/2" x 1/2" OPENINGS
FINISH:	MILL

SIZE LIMITATIONS: SINGLE SECTION LOUVER

	MINIMUM	MAXIMUM
WIDTH	10" (254 mm)	72" (1829 mm)
HEIGHT	10" (254 mm)	120" (3048 mm)
AREA	0.7 ft ² (0.06 m ²)	60 ft ² (5.57 m ²)

*LOUVER WILL BE MANUFACTURED 1/4" (6.4 mm) SMALLER (SINGLE SECTION) AND 1/2" (12.7 mm) SMALLER (MULTIPLE SECTION) THAN GIVEN OPENING DIMENSIONS UNLESS OTHERWISE SPECIFIED

AVAILABLE ACCESSORIES

FINISH: - BAKED ENAMEL FINISH - DURANAR FINISH - ANODIZED FINISH - CLEAR ANODIZED - LIGHT BRONZE - MEDIUM BRONZE - DARK BRONZE - BLACK ANODIZED - EXTENDED SILLS - SECURITY BARS - FILTER RACKS - STAINLESS STEEL FASTENERS - HINGED ACCESS DOORS - ALL WELDED CONSTRUCTION - CUSTOM GEOMETRIC SHAPES - CONTINUOUS LINE CONSTRUCTION IS <u>NOT</u> RECOMMENDED*		
SCREENS: - BIRDSCREEN 1/2" x 1/2" INTER CRIMPED ALUMINUM - ALUMINUM BIRDSCREEN WITH FRAME - INSECT SCREEN 18 x 14 MESH		
BLANK-OFF PANELS (ALUMINUM): VARIOUS GAUGES - NON-INSULATED BLANK-OFF PANELS - INSULATED BLANK-OFF PANELS 1" (25.4 mm) INSULATION 2" (50.8 mm) INSULATION		




2630 / 2635

6" DEEP DRAINABLE LOUVER

FREE AREA (Sq. Ft.)


	WIDTH (INCHES)																	
	10	12	16	20	24	28	32	36	40	44	48	52	56	60	64	68	72	
HEIGHT (INCHES)	10	0.31	0.39	0.55	0.71	0.87	1.03	1.19	1.35	1.51	1.67	1.83	1.99	2.15	2.31	2.47	2.63	2.79
	12	0.32	0.40	0.57	0.73	0.90	1.06	1.23	1.40	1.56	1.73	1.89	2.06	2.22	2.39	2.55	2.72	2.88
	16	0.33	0.42	0.59	0.76	0.93	1.10	1.27	1.44	1.61	1.78	1.96	2.13	2.30	2.47	2.64	2.81	2.98
	20	0.48	0.60	0.85	1.10	1.35	1.59	1.84	2.09	2.34	2.58	2.83	3.08	3.33	3.57	3.82	4.07	4.32
	24	0.64	0.81	1.14	1.47	1.80	2.13	2.46	2.80	3.13	3.46	3.79	4.12	4.45	4.78	5.12	5.45	5.78
	28	0.81	1.02	1.44	1.86	2.28	2.70	3.12	3.54	3.96	4.38	4.80	5.22	5.64	6.06	6.48	6.90	7.32
	32	0.99	1.24	1.75	2.26	2.76	3.27	3.78	4.29	4.80	5.31	5.82	6.32	6.83	7.34	7.85	8.36	8.87
	36	1.11	1.40	1.97	2.54	3.11	3.69	4.26	4.83	5.40	5.98	6.55	7.12	7.70	8.27	8.84	9.41	9.99
	40	1.27	1.60	2.26	2.91	3.57	4.22	4.88	5.54	6.19	6.85	7.51	8.16	8.82	9.47	10.13	10.79	11.44
	44	1.37	1.73	2.43	3.14	3.85	4.56	5.26	5.97	6.68	7.39	8.09	8.80	9.51	10.22	10.93	11.63	12.34
	48	1.55	1.95	2.75	3.55	4.35	5.15	5.96	6.76	7.56	8.36	9.16	9.96	10.76	11.56	12.36	13.16	13.96
	52	1.70	2.14	3.02	3.90	4.78	5.66	6.54	7.42	8.30	9.18	10.06	10.94	11.82	12.69	13.57	14.45	15.33
	56	1.85	2.33	3.29	4.24	5.20	6.16	7.11	8.07	9.03	9.98	10.94	11.90	12.85	13.81	14.76	15.72	16.68
	60	2.01	2.53	3.57	4.61	5.65	6.69	7.73	8.77	9.81	10.85	11.89	12.93	13.97	15.01	16.05	17.09	18.13
	64	2.19	2.75	3.88	5.01	6.13	7.26	8.39	9.52	10.65	11.78	12.90	14.03	15.16	16.29	17.42	18.55	19.67
	68	2.36	2.97	4.18	5.40	6.62	7.83	9.05	10.27	11.48	12.70	13.92	15.13	16.35	17.57	18.78	20.00	21.22
	72	2.48	3.12	4.40	5.68	6.97	8.25	9.53	10.81	12.09	13.37	14.65	15.93	17.21	18.50	19.78	21.06	22.34
	76	2.64	3.33	4.69	6.06	7.42	8.78	10.15	11.51	12.88	14.24	15.61	16.97	18.34	19.70	21.07	22.43	23.79
	80	2.74	3.45	4.87	6.28	7.70	9.12	10.53	11.95	13.36	14.78	16.20	17.61	19.03	20.44	21.86	23.28	24.69
	84	2.92	3.68	5.19	6.70	8.21	9.71	11.22	12.73	14.24	15.75	17.26	18.77	20.28	21.79	23.30	24.81	26.31
88	3.08	3.87	5.46	7.04	8.63	10.22	11.81	13.40	14.98	16.57	18.16	19.75	21.33	22.92	24.51	26.10	27.68	
92	3.23	4.06	5.72	7.39	9.05	10.72	12.38	14.05	15.71	17.38	19.04	20.71	22.37	24.03	25.70	27.36	29.03	
96	3.39	4.26	6.01	7.76	9.50	11.25	13.00	14.75	16.50	18.24	19.99	21.74	23.49	25.24	26.98	28.73	30.48	
100	3.56	4.48	6.31	8.15	9.99	11.82	13.66	15.50	17.33	19.17	21.01	22.84	24.68	26.52	28.35	30.19	32.02	
104	3.73	4.69	6.62	8.54	10.47	12.39	14.32	16.24	18.17	20.09	22.02	23.94	25.87	27.79	29.72	31.64	33.57	
108	3.85	4.85	6.84	8.83	10.82	12.81	14.80	16.79	18.77	20.76	22.75	24.74	26.73	28.72	30.71	32.70	34.69	
112	4.02	5.05	7.13	9.20	11.27	13.34	15.42	17.49	19.56	21.64	23.71	25.78	27.85	29.93	32.00	34.07	36.15	
116	4.12	5.18	7.30	9.43	11.55	13.68	15.80	17.92	20.05	22.17	24.30	26.42	28.55	30.67	32.80	34.92	37.04	
120	4.26	5.36	7.56	9.76	11.96	14.17	16.37	18.57	20.77	22.97	25.17	27.37	29.57	31.77	33.97	36.17	38.37	

WATER PENETRATION - 2630 / 2635
15 MINUTE DURATION, TEST SIZE 48" x 48"



BEGINNING POINT OF WATER PENETRATION AT 0.01 oz./ft² FREE AREA IS 1080 FPM

PRESSURE DROP - 2630 / 2635
FIGURE 5.5, TEST SIZE 48" x 48"



*TEST RESULTS DO NOT INCLUDE THE EFFECTS OF BIRDSCREEN

RECOMMENDED SPECIFICATION

Furnish and install stationary louver models 2630 / 2635 as manufactured by Ventex Inc., Alliston, Ontario. Louvers must be licensed to bear the AMCA seal. Louvers shall be 6" (152 mm) deep. Blades shall be 0.081" (2.06 mm) extruded 6063-T5 aluminum alloy and frame shall be 0.095" (2.41 mm) extruded 6063-T5 aluminum alloy. Louvers shall have 19 gauge galvanized ½" x ½" birdscreen. All materials shall be factory finished after assembly with Polyester Power Coat in a color selected from the Ventex Color Chart.

CERTIFIED RATINGS

Ventex Inc. certifies that the models 2630 / 2635 shown here are licensed to bear the AMCA Seal. The ratings shown are based on tests and procedures performed in accordance with AMCA Publication 511 and comply with the requirements of the AMCA Certified Ratings Program. The Certified Ratings Seal applies to air performance and water penetration ratings.



Certification